

budynek A2

	V (m3/h)	spręż dysp. (Pa)	Reg. RH	Filtr	czynnik chłodniczy	temp.za nagrz. zima	parametry nawiewu dla lata po osuszaniu temp/RH	Qch [kW]	Qg I st. [kW]	Uwagi
N-1	25840	620	40-65%	F5+F9	glikol	34	18/60%	276	303	nawilżacz wodny
W-1	25840	350	-	F4	-					
N-2	2980	600	40-65%	F5+F9	glikol	34	18/60%	28,1	35	nawilżacz wodny
W-2	2980	280	-	F4	-					
N-3	12015	450	nie kontrolowana	F5+F9	glikol	20	19/n.k.	54,6	96,7	
W-3	10365	350	-	F4	-					
N-4	4155	350	nie kontrolowana	F5	glikol	20	19/n.k.	18,9	52,9	
W-4	3175	300	-	F4	-					