

OBLICZENIA

Wyniki - Zestawienie pomieszczeń

Symbol	Opis	$\theta_{int,H}$	A	V	n_{min}	V_{min}	Φ_T	Φ_V	H_T	H_V	Φ	$\Phi_{HL,c}$
		°C	m ²	m ³	1/h	m ³ /h	W	W	W/K	W/K	W	W
-01	Pom. techniczne	12,0	24,72	91,5	1,00	91,5	737	995	23,03	31,10	1732	2177
01	Szatnia	20,0	47,76	195,8	0,50	97,9	3234	1331	80,84	33,29	4565	5425
02	Korytarz	16,0	96,59	396,0	0,50	198,0	-292	2424	-8,10	67,32	2132	3871
11	Hol dla studentów	20,0	137,04	507,0	0,50	253,5	3491	3448	87,29	86,20	6939	9406
12	Korytarz	16,0	93,34	345,4	0,50	172,7	2179	2114	60,52	58,71	4292	5972
13	Korytarz	16,0	41,71	154,3	0,50	77,2	995	944	27,63	26,24	1939	2690